

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7254-0075:0229

CATEGORY: 7254 -- HEAT DETECTOR (SINGLE/MULTIPLE)

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Vladimir Kireyev (203) 484-7161 Fax (203) 484-7309
Email: vladimir.kireyev@Honeywell.com

DESIGN: Models W-H355 and W-H355R Electronic fixed temperature heat detectors,. Model W-H355 is a 135°F electronic fixed temperature heat detector. Model W-H355R is a 135°F electronic fixed temperature heat detector with 15°F/min rate-of-rise. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 3.2 Vdc lithium battery Panasonic Type CR123A or Duracell Type DL123A. Four batteries are used in parallel connection.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as electronic fixed temperature heat detectors for use with System Sensor bases B210W or B501W (CSFM No. 7300-1653:0233) and compatible fire alarm control panels. Refer to listee's Installation Instruction Manual for details.

XLF: 7254-0028:0270

07-01-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division