

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-1653:0186 Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

DESIGN: Synchronous type strobe lights, Models SR, SRH, SW, SW-CLR-ALERT, SWH, SCR, SCRH, SCW, SCW-CLR-ALERT and SCWH followed by the suffix -P, -SP, -PG, or none.

Intended for indoor use mounted on the wall or the ceiling. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 8-17.5 or 16-33 VDC/FWR
Candela: 15, 15/75, 30, 75, 95, 110, 115, *135, *150, *177, *185cd

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights suitable for hearing impaired application when used with separately listed compatible fire alarm control units. Suitable for indoor use, wall or ceiling mounted. Refer to listee's Installation Instruction Manual for details.

*Rev. 03-11-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGAN, Program Coordinator**
Fire Engineering Division