

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0075:0231 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653  
Contact: Vladimir Kireyev (203) 484-7161 Fax (203) 484-7309  
Email: vladimir.kireyev@Honeywell.com

**DESIGN:** Model ANN-LC allows the MS-9050UD to become a common central station communicator for multiple MS-9050UD and MS9200UDLS fire alarm control panels. The ANN-LC provides communication between up to 16 control units and a Master control unit for alarm and trouble reporting to a supervising station receiver. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 24VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical ratings, and UL Label

**APPROVAL:** Listed as fiber module for use with listee's separately listed fire alarm control units. Refer to manufacturer's Installation Manual for details.

07-01-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

*Listing Expires* **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
*Fire Engineering Division*