

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7272-1615:0250 Page 1 of 1

**CATEGORY:** 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

**LISTEE:** BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450  
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263  
Email: jon.wolski@us.bosch.com

**DESIGN:** Models FAP-325-V2F analog addressable photoelectric type smoke detector with listed compatible bases, Bosch Model FAA-325-B4 or FAA-325-B6 (CSFM Listing No. 7300-1615:0235). Unit consists of resistors, capacitors, diodes, transistors, LED, photo diode, mounted on a printed wiring board inside an enclosure. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 39.5 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as photoelectric smoke detector for use with separately listed compatible fire alarm control units. Also suitable for in-duct use in air velocities up to 4000 ft/min. Refer to listee's Installation Instruction Manual for details.

**XLFF:** 7272-0410:0173

03-19-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*