

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7120-0075:0222

Page 1 of 1

CATEGORY: 7120 -- ANNUNCIATORS

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Vladimir Kireyev (203) 484-7161 Fax (203) 484-7309
Email: vladimir.kireyev@Honeywell.com

DESIGN: Models ANN-LED, ANN-RLED Remote Annunciators, and ANN-RLY Relay Module. Models ANN-LED and ANN-RLED provide remote annunciation of up to 10 inputs (ANN-LED) and 30 inputs (ANN-RLED). Model ANN-RLY relay module provides 10 programmable Form C relays. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as annunciators or relay module for use with listee's separately listed fire alarm control units. Refer to Manufacturers Installation Instruction Manual for details.

NOTE:

04-16-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division