

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7167-1615:0243

Page 1 of 2

**CATEGORY:** 7167 -- CONTROL UNIT (HOUSEHOLD)

**LISTEE:** BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450  
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263  
Email: jon.wolski@us.bosch.com

**DESIGN:** Model D7212GV4, D7412GV4 and D9412GV4 residential fire alarm control units.  
Refer to listee's data sheet for additional detailed product description and operational considerations.

System components:

D720/1255/1256/1257/1260; Command Centers

D122/122L; Dual Battery Harness

D125B; Powered Loop Interface Module

D126; 12V, 7Ah Battery

D127; Relay

D129; Initiating Circuit Module

D130/D133; Relay Module

D161/D162; Phone Cord

D5300; Remote Account Manager II

D8121A; Subscriber Terminal Unit

D8125; POPEX Module

D9127T, 9127U; POPIT Module

D8128D; OctoPOPIT Module

D1640; Transformer

D8103/8109/8108A; Enclosures

D8129; OctoRelay Module

D8130; Release Module

D8132; Battery Charger Module

D9131/D9131A; Printer Interface

DX4020; B420; Network Interface Module

ITS-DX4020-G; GPRS/GSM IP Communicator

ICP-SDI-9114; Splitter/Isolator

B208; Input Module

B308; Output Module

\*B440, \*B441; Cellular Modules

\*B450; Interface Module

\*B915, \*B920, \*B921C, \*B921CW, \*B930, \*B942, \*942W; Keypads

\*B56; Surface Mount Backbox

D9210C; Access Control Module

B820 Wireless receiver

\*Rev 04-22-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
*Fire Engineering Division*

D928; Dual Phone Line Switcher Module  
 D192G; Notification Appliance Circuit Module  
 D8004; Transformer Enclosure  
 D8125MUX; POPEX Module  
 D9210B, D9210BC, D9210BLC, D9210C; Access Control Interface Module  
 ITS-DX4020-G; GPRS/GSM IP Communicator  
 D1255RB/D1256RB/D1257RB; Keypads/Annunciators

- INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
- MARKING:** Listee's name, model number, electrical rating, and UL label.
- APPROVAL:** Listed as household fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to listee's Installation Instruction Manual for details. For fire alarm use, the secondary (standby) power supply shall supply energy during power loss to operate a protected premises, central station, or proprietary system for 24 hours or an auxilliary or remote station system for 60 hours in the normal condition followed by not less than 5 minutes of alarm as required by code. These control units can generate a distinctive three- pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72.
- NOTE:**
- 1) For household system, Fire Alarm Verification Feature (delay of fire alarm signal) is NOT approved for use in California. This feature shall not be programmed into the unit.
  - 2) Burglary and other non-fire functions were not examined.

\*Rev 04-22-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**  
*Fire Engineering Division*