

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3240-1615:0184 Page 1 of 1

CATEGORY: 3240 -- DUCT SMOKE DETECTOR HOUSING/BASE

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263
Email: jon.wolski@us.bosch.com

DESIGN: Model D340 duct smoke detector housing. The unit consists of a thermal plastic enclosure, listed open area detector Model D285DH (CSFM Listing No. 7272-1615:134) or D286 (CSFM Listing No. 7271-1615:136), a sampling and an exhaust tube. *Model D340 may be used with Model D344RT or Model D344RL remote test and indicator plate accessories or Model DRA-5 remote alarm indicator. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 12/24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as duct detector housing for use with listee's separately listed fire alarm control units. Suitable for air velocity between 300-4000 ft/min.

*Rev. 04-22-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division