

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0075:0233 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653  
Contact: Vladimir Kireyev (203) 484-7161 Fax (203) 484-7309  
Email: vladimir.kireyev@Honeywell.com

**DESIGN:** Model W-MMF Wireless Monitor Module. The input to the monitor module is non-latching and does not require a reset. The device communicates through a bi-directional mesh network to the gateway and/or FACP. Rotary decade switches are provided for setting the module's address. The module has a panel controlled LED indicator. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 3.3 Vdc

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a wireless monitor module intended to be used with a compatible wireless fire alarm control panel\*. Refer to listee's Installation Instruction Manual for details.

**XLF:** 7300-0028:0273

\*Corrected 12-04-14 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

*Listing Expires* **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
*Fire Engineering Division*