

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0559:0500

Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: SILENT KNIGHT SECURITY One Fire-Lite Place, Northford, CT 06472-1653
Contact: Vladimir Kireyev (203) 484-6277 Fax (203) 484-7309
Email: Vladimir.Kireyev@honeywell.com

DESIGN: Silent Knight Model 6820 and 6820-EVS, Fire Alarm Control Unit, automatic, manual, local, remote station (PPU), central station (PPU), releasing (water deluge only) and mass notification services (6820-EVS).

Model 6820 System Components:

- 5860 Remote Annunciator
- 6855 Remote Annunciator
- 6860 Remote Annunciator
- 5496 NAC Expander
- 5880 LED I/O Module
- 5865-3 Remote LED Annunciator
- 5865-4 Remote LED Annunciator
- 5883 Relay Interface
- 5824 Serial/Paralell Printer Interface Module
- 5895XL Power Supply
- SK-NIC Network Inerface Card
- SK-FML Mulit Mode Fiber Card
- SK-FSL Single Mode Fiber Card
- CELL-MOD Celular Communicator in Plastic Enclosure
- CELL-CAB-SK Cellular Communicator in Metal Enclosure with Lock & Key
- RBB Remote Battery Box (16"WX10"HX6"D)
- SK-SKC Seismic Complaince Kit
- *5815XL SLC Expander
- *6815 SLC Expander

Model 6820EVS System Components:

- EVS-50W 50 Watt Amplifier
- EVS-100W 100 Watt Amplifier
- EVS-125W 125 Watt Amplifier
- EVS-100WBU External Backup Amplifier
- EVS-INT50W 50 Watt Internal Amplifier
- EVS-CE4 Circuit Audio Expander

*Rev 01-02-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **July 01, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division

EVS-SW24 24 Switch Expander
 EVS-VCM Voice Control Module
 EVS-LOC Local Operator Control
 5860 Remote Annunciator
 6855 Remote Annunciator
 6860 Remote Annunciator
 5496 NAC Expander
 5880 LED I/O Module
 5865-3 Remote LED Annunciator
 5865-4 Remote LED Annunciator
 5883 Relay Interface
 5824 Serial/Paralell Printer Interface Module
 5895XL Power Supply
 SK-NIC Network Inerface Card
 SK-FML Mulit Mode Fiber Card
 SK-FSL Single Mode Fiber Card
 CELL-MOD Celular Communicator in Plastic Enclosure
 CELL-CAB-SK Cellular Communicator in Metal Enclosure with Lock & Key
 RBB Remote Battery Box (16"WX10"HX6"D)
 SK-SCK Seismic Complaince Kit
 *5815XL SLC Expander
 *6815 SLC Expander

RATING: Primary Operating Power Supply:
120VAC, 60HZ, 3.25A

Secondary Operating Power Supply:
24VDC, 750 mA, 55Ah

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a commercial fire alarm control unit for use with separately listed initiating and indicating devices and for mass notification. Refer to listee's Installation Instruction Manual for details.

*Rev 01-02-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **July 01, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division