

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 6911-1446:0100  
**CATEGORY:** 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

Page 1 of 1

**LISTEE:** EVAX SYSTEMS20 McDermott Dr, Branford, CT 06405  
Contact: Peter Binkley (203) 315-5116 Fax (203) 315-5118  
Email: p.binkley@evax.com

**DESIGN:** Models EVAX 25, -25E, -50, -50E, -100, -100E, -150, -150E, -200, -200E audio adjunct system. These units are intended to be used in conjunction with a listed electrically compatible fire alarm control unit to provide voice communication, paging, evacuation tone signals, and voice alarm signals with voice override. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** Input: 24-32 VAC/DC, Standby:\* 24 VDC, EVAX 25 / 25E / 50/ 50E 7-18 Ah Battery  
EVAX 100 / 100E 7-24 Ah Battery

**INSTALLATION:** In accordance with listee's printed installation instructions, wiring diagram, applicable codes and ordinances and in a manner which is acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as a voice/tone communication/evacuation/relocation/audio adjunct system for use with separately listed electrically compatible fire alarm speakers and control units. Supervision is dependent upon the fire alarm control panel. Refer to the control panel's listing and installation instructions for proper configurations. Suitable for high rise applications when used in conjunction with separately listed fire alarm control units. Refer to listee's Installation Instruction Manual for details.

\*Rev 9-26-08 ma



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
*Fire Engineering Division*