

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0075:0174 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Vladimir Kireyev (203) 484-7161 Fax (203) 484-7309
Email: vladimir.kireyev@Honeywell.com

DESIGN: Models UDACTF, 411, 411-UD and 411UDAC digital alarm communicator transmitter and Model ABS-8RF enclosure (for use with Model UDACTF only). The UDACTF, 411, 411UD and 411UDAC units are intended to provide central station service over a standard two-wired telephone switching network. The UDACTF is for use with listee's separately listed fire alarm control units. The 411, 411UDAC and 411-UD are for use with any UL and CSFM listed control units. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: UDACTF: 21.2 - 28.2 VDC
411, 411-UD: 11.7 - 12.4 VDC (nominal) or 21.3 - 24.0 VDC (nominal)
411UDAC: 120 VAC, 12 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, electrical rating, and UL label.

APPROVAL: Listed as digital alarm communicator transmitters for use with listee's separately listed electrically compatible fire alarm control units.

NOTE:

*Rev. 05-06-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division