

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7165-0992:0138  
**CATEGORY:** 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

Page 1 of 1

**LISTEE:** Napco333 Bayview Avenue, Amityville, NY 11701  
Contact: Alan Shaw (631) 842-9400 Fax (631) 842-2726  
Email: ashaw@napcosecurity.com

**DESIGN:** Model GEMC-32, GEMC-96, GEMC-128, and GEMC-255 fire alarm control units. Automatic, manual, waterflow and sprinkler supervisory service, local, remote station (PPU) and central station (PPU). Refer to listee's data sheet for detailed product description and operational considerations. System components:

GEMC-HSKIT1416, HSKIT1425; Enclosure  
GEMC-32MB, GEMC-96MB, GEMC-128MB, GEMC-255MB; Main Boards  
GEMC-PS24V4A, GEMC-PS24V7A; Power Supply  
GEMC--FW-SLC; Fire Signaling Line Circuit Modules  
GEMC-F8ZCPIM; Zone Expander Modules  
GEMC-24VR; 24V Output Module

**RATING:** 120 VAC, 12 and 24 VDC

**INSTALLATION:** In accordance with listee's printed installation instructions and applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or UL File number, model number, electrical rating and UL label.

**APPROVAL:** Listed as fire alarm control units for use with separately listed compatible initiating and indicating devices. Refer to manufacturer's Installation Manual for details.

This control unit meets the requirements of Standard UL-864, 9th Edition.

12-09-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **July 01, 2015**

Authorized By: **JAMES PARSEGAN, Program Coordinator**  
*Fire Engineering Division*