

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

Page 1 of 1

LISTING No. 7260-1728:0121

CATEGORY: 7260 -- SMOKE DETECTION SYSTEM-BEAM TYPE

LISTEE: XTRALIS, INC. 175 Bodwell Street, Avon, MA 02322
Contact: Mark Schofield (781) 616-1105 Fax (781) 681-3149
Email: mschofield@xtralis.com

DESIGN: Models OSI-10, OSI-45, OSI-90 projected beam type smoke-automatic fire alarm. Units are comprised of an imager and emitter device. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 20 - 30 vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as air sampling type smoke-automatic fire detectors. Refer to listee's Installation Instruction Manual for details.

08-11-11 mt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division