

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7770-1653:0170

Page 1 of 1

CATEGORY: 7770 -- VALVES/SWITCHES

LISTEE: System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

DESIGN: Model PSP1 plug in valve position supervisory switch. Suitable for outdoor use. This unit is not intended or designed for ordinary use. To be used for unusual conditions such as pit valves and pumping sites, non-rising stem gate valves where no other approved method of protection is available or practical. Also, has an enclosure rating equivalent to a NEMA 3 rating. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 6/12/24 VAC/VDC, 250 mA

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a valve supervisory switch for use in special applications only. Not intended or designed for ordinary uses or in fire protection systems. Refer to listee's Installation Instruction Manual for details.

NOTE: 1. As this unit does not meet NFPA Codes and Standards (requiring restoration of the signal when the valve is positioned to normal), special attention should be given by the responsible parties to assure that the proper operation of this device is maintained. This device should only be restored to normal when the valve is in normal condition.

2. Formerly 1030-1209:230

06-20-05



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2014**

Listing Expires **June 30, 2015**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division