

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1615:0235 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263
Email: jon.wolski@us.bosch.com

DESIGN: Models FAA-325-B4 and FAA-325-B6 Detector bases. Unit is intended for use with a separately listed compatible detector head. Refer to listee's data sheet for detailed product description and operational considerations. Models listed below.

FAH-325 Analog Heat Detector
FAI-325 Analog Ionization Smoke Detector
FAP-325 Analog Photoelectric Smoke Detector

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as bases for use with listee's separately listed compatible smoke and heat detectors. Refer to heat or smoke detector listings for compatibility.*

XLF: 7300-0410:0132

fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division