

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-1653:0188

Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

DESIGN: Models CHSR and CHSW Chime/Strobes.
Models P2R, P2W, P2RH and P2WH Horn/Strobes two-wire type, rectangular enclosure.
Models PC2R, PC2W, PC2RH and PC2WH Horn/Strobes two-wire type, round enclosure
Models P4R, P4W, P4RH and P4WH Horn/Strobes four-wire type, rectangular enclosure.
Models PC4R, PC4W, PC4RH and PC4WH Horn/Strobes* four-wire type, round enclosure.
All models are intended for indoor use only unless other wise indicated. Models may be followed by the suffix "K" indicating indoor or outdoor use, or may be followed by suffix "P" for plain housing with no lettering. "K" suffix models are suitable for outdoor applications at temperatures from -40°F to +151°F (-40°C to +66°C) and are rated NEMA 4X when used with the System Sensor weather proof back boxes models SA-WBB (Wall), SA-WBBW (Wall), SA-WBBC (Ceiling) and *SA-WBBCW (Ceiling). Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Standard Horn/Strobes and Chime/Strobes 8 - 17.5 or 16-33 VDC/FWR
Hi CD Horn/Strobes 16-33 VDC/FWR

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as *horn/strobes or chime/strobes suitable for signaling appliances and equipment for the hearing impaired applications when used with separately listed compatible fire alarm control units. Horn/strobes with -K suffix are suitable for indoor or outdoor use, ceiling or wall mount. Chime section is suitable for private mode and indoor use only.
Horn/Strobes or chime/strobes* can generate the distinctive three-pulse audible Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2010 Edition. Refer to listee's Installation Instruction Manual for details.

*Corrected 12-15-11 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division