

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-1653:0223 Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

DESIGN: Models HR-LF and HW-LF horns. Intended for indoor use and suitable for wall or ceiling mount.
Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 8-17.5 or 16-33 Vdc/VFWR

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as audible devices when used with separately listed compatible fire alarm control units. Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal. *These units can generate a low frequency alarm signal for sleeping areas in accordance with NFPA 72. Refer to manufacturer's Installation Manual for details.

*Rev 07-22-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division