

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-1615:0244 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450  
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263  
Email: jon.wolski@us.bosch.com

**DESIGN:** Models FAA-440-B4 analog standard 4 inch, FAA-440-B6 analog standard 6 inch, FAA-440-B4-ISO analog isolator 4 inch, and FAA-440-B6-ISO analog isolator 6 inch bases. Units are intended for use with listee's separately listed compatible detector heads. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 24-41Vdc, 10 mA

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model designation, electrical rating and UL label.

**APPROVAL:** Listed as bases for use with listee's separately listed compatible smoke and heat detectors.

03-13-12 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

*Listing Expires* **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator  
*Fire Engineering Division*