

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0785:0178 Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Tom Conover (941) 487-2336
Email: thomas.conover@cooperindustries.com

DESIGN: Models LSPSTxC and *LSPSTxC-A Ceiling Speaker Strobe. The letter 'x' indicates product color. The model number may be followed by a hyphen and one or two alphanumeric characters indicating lettering. *An "A" on the end indicates amber lens. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 25 or 70 Vrms speaker
16-33 VDC strobe

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as speakers-strobe for use with separately listed electrically compatible fire alarm control units. For ceiling mounted indoor use only. Refer to listee's Installation Instruction Manual for details.

*Rev 11-03-15 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division