

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1691:0104 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: COOPER MEDC3413 North Sam Houston Pkwy West, Houston, TX 77086
Contact: Joel Weinberg (713) 937-9772 Fax (713) 937-9773
Email: joel.weinberg@cooperindustries.com

DESIGN: Models XB15 high intensity strobe warning light and FB15 steady burning light. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: XB15: 520,000 candela
NEMA 4x and 6

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as strobe warning light for use with separately listed compatible fire alarm control units. Suitable for indoor and outdoor. Model XB15 is for use in Class I, Div, 2, Groups A, B, C, D; Class II, Div. 2, Groups F, G. Model FB15 is for use in Class I, Div, 2, Groups A, B, C, D.

NOTE: Not suitable for the hearing impaired application

05-27-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSEGIAN, Program Coordinator**
Fire Engineering Division