

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 6911-0075:0226 Page 1 of 1

CATEGORY: 6911 -- VOICE COMMUNICATION SYSTEMS CONTROL UNITS

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Vladimir Kireyev (203) 484-7161 Fax (203) 484-7309
Email: vladimir.kireyev@Honeywell.com

DESIGN: Models ECC-50/100 and ECC-50/100E. These are 50-watt audio emergency voice evacuation panels expandable to 100-watt for fire applications, mass notification applications, or both. Refer to listee's data sheet for additional detailed product description and operational considerations. System components:

ECC-MCB; Main Control Board
ECC-DKVCM; Display Board
ECC-50W-25V; Amplifier Module 25 VRMS
ECC-50W-70V; Amplifier Module 70 VRMS
ECC-MCB; Main Control Board
ECC-DKVCM; Display Board
ECC-50W-25V; Amplifier Module 25 VRMS
ECC-50W-70V; Amplifier Module 70 VRMS
ECC-CE6; Speaker Circuit Expander Module
ECC-XRM-70V; Transformer Module 70.7 VRMS

RATING: Primary Operating: 120 V, 60 Hz, 3.5 A or 240 V, 50 Hz, 2 A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as voice communication systems for use with separately listed compatible fire alarm control units to provide emergency voice evacuation signals. Refer to listee's Installation Instruction Manual for details.

05-02-13 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **July 01, 2016**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division