

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-0075:0232 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: FIRE-LITE ALARMS INC. One Fire-Lite Place, Northford, CT 06410-1653
Contact: Vladimir Kireyev (203) 484-7161 Fax (203) 484-7309
Email: vladimir.kireyev@Honeywell.com

DESIGN: Model W-Gate wireless gateway and Model W-DIS-D wireless driver. Model W-Gate receives wireless IDC data from compatible wireless detectors and wireless initiating modules and this information is passed on to compatible fire alarm control panel via hard wire. Model W-DIS-D is wireless driver that receives trouble information from compatible wireless detectors and wireless initiating modules and passed it on to remote fire Annunciator Model ANN-80 (CSFM No. 7120-0075:0211) for display. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 24 Vdc nominal voltage, 30 mA.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as an ancillary device intended to be installed in the manufacturer's listed, compatible fire alarm control panel enclosure. Refer to listee's Installation Instruction Manual for details.

XLf: 7300-0028:0272

08-13-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2016**

Listing Expires **June 30, 2017**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division