

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7135-0785:0127

Page 1 of 1

CATEGORY: 7135 -- AUDIBLE DEVICES

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Tom Conover (941) 487-2336
Email: thomas.conover@cooperindustries.com

DESIGN: Model AMT-12/24 multitone audible device*.

Unit may follow by suffixes to designate lens orientation, lettering and plate color. Models AMT are switchable between nominal 12 and 24 VDC with high and low output. The unit can provide one of nine tone outputs. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: -12: 8-17.5 VDC*
-24: 16-33 VDC*

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to authority having jurisdiction.

MARKING: Listee's name, model number, rating and UL label.

APPROVAL: Listed as audible/visual signal device for use with separately listed compatible control units. Suitable for outdoor when installed with weatherproof back box. Not approved for the hearing impaired applications.

These appliances can produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to manufacturer's Installation Manual for details.

*Rev. 05-25-10 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division