

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7135-1653:0189

Page 1 of 1

**CATEGORY:** 7135 -- AUDIBLE DEVICES

**LISTEE:** System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174  
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245  
Email: trish.linhart@systemsensor.com

**DESIGN:** Models HR, HW Horns and CHR, CHW chimes. Intended for indoor use only unless otherwise indicated. Models may be followed by the suffix "K" indicating indoor or outdoor use. "K" suffix models are suitable for outdoor applications at temperatures from -40°F to +151°F (-40°C to +66°C) and are rated NEMA \*4X when used with the System Sensor weather proof back boxes models SA-WBB (Wall), \*SA-WBBW (Wall), SA-WBBC (Ceiling) and \*SA-WBBCW (Ceiling). Models CHR and CHW are intended for private mode use only. Suitable for wall or ceiling mount.  
Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 8 - 17.5 or 16-33 Vdc/VFWR

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating, and UL label.

**APPROVAL:** Listed as audible devices when used with separately listed compatible fire alarm control units.

Units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer to listee's Installation Instruction Manual for details.

\*Rev 12-01-08 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**  
*Fire Engineering Division*