

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1653:0187 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: System Sensor, Unincorporated Div of Honeywell Int'l Inc. 3825 Ohio Ave, St. Charles, IL 60174
Contact: Trish Linhart (630) 762-5025 Fax (630) 377-7245
Email: trish.linhart@systemsensor.com

DESIGN: Models SWK, SWHK, SCWK, SCWHK, SRK, SRHK, SCRK and SCRHK strobe lights intended for indoor or outdoor use and may be mounted on the wall or the ceiling. These strobe lights are suitable for outdoor use at an operating temperature range of -40°F to 150°F (-40°C to 66°C)* rating and are NEMA 4X rated when used with the Listed models SA-WBB (wall), SA-WBBW (Wall) or the model SA-WBBC (ceiling), SA-WBBCW (Ceiling) weatherproof back boxes. May be followed by suffix -P for plain housing with no lettering. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: 8-17.5 or 16-33 VDC/FWR

INSTALLATION: In accordance with listee's printed installation instruction, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as strobe lights for general signaling. For indoor or outdoor use. Refer to listee's Installation Instruction Manual for details.

NOTE: Not approved for public mode and not to be used as an evacuation signal for the hearing impaired.

*Corrected 07-22-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division