

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 3774-1725:0100

Page 1 of 1

CATEGORY: 3774 -- ELECTRIC LOCKS

LISTEE: STANLEY SECURITY SOLUTIONS 6161 E. 75th Street, Indianapolis, IN 46250
Contact: Robert Strong (317) 806-3288 Fax (317) 806-3337
Email: bstrong@stanleyworks.com

DESIGN: Models DE2100 (single point rim exit device), DE2200 (surface mounted vertical rod) with suffix "LBR", DE2300 (single point mortise) with prefix "E", DE2700 and DE2800 (concealed vertical rod) with suffix "LBR", Special Locking Arrangement and Controlled Exit Panic devices. These units are universal logic and power controllers used as delayed exit control systems which allows exit when power loss occurs or when a fire is detected. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as Special Locking Arrangement and Controlled Exit Panic devices for use with swinging type doors as a mean of supplemental locking of the door in addition to the door's required latching mechanism when installed in accordance with the California Building Code, Section 1003.3.1.10 Special egress-control devices. Authority having jurisdiction shall be consulted prior to installation.

05-13-09 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2013**

Listing Expires **June 30, 2014**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division