

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7270-1615:0108 Page 1 of 1

CATEGORY: 7270 -- HEAT DETECTOR

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263
Email: jon.wolski@us.bosch.com

DESIGN: Models F220-135, -135F, and -190F fixed temperature heat detectors. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: F220-135 135° fixed temperature with 15° rate of rise
F220-135F 135° fixed temperature
F220-190F 190° fixed temperature

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as heat detectors for use with separately listed compatible fire alarm control units and Model F220-B6 series detector bases (CSFM Listing No. 7300-1615:105). Refer to listee's Installation Instruction Manual for details.

07-21-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division