

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7165-0559:0501 Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: SILENT KNIGHT SECURITY One Fire-Lite Place, Northford, CT 06472-1653
Contact: Vladimir Kireyev (203) 484-6277 Fax (203) 484-7309
Email: Vladimir.Kireyev@honeywell.com

DESIGN: Silent Knight Model 6700, Fire Alarm Control Unit, automatic, manual, local, remote station (PPU), central station (PPU), releasing (water deluge only).

Model 6700 System Components:

- 5860 Remote Annunciator
- 6855 Remote Annunciator
- 6860 Remote Annunciator
- 5496 NAC Expander
- 5880 LED I/O Module
- 5865-3 Remote LED Annunciator
- 5865-4 Remote LED Annunciator
- 5883 Relay Interface
- 5824 Serial/Paralell Printer Interface Module
- 5895XL Power Supply
- SK-NIC Network Inerface Card
- SK-NIC-KIT Network Interface Card in Cabinet
- SK-FML Mulit Mode Fiber Card
- SK-FSL Single Mode Fiber Card
- CELL-MOD Celular Communicator in Plastic Enclosure
- CELL-CAB-SK Cellular Communicator in Metal Enclosure with Lock & Key
- RBB Remote Battery Box (16"WX10"HX6"D)
- SK-SCK Seismic Complaince Kit

RATING: Primary Operating Power Supply:
120VAC, 60HZ, 1.5A

Secondary Operating Power Supply:
24VDC, 3.1A, 35Ah

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating, and UL label.

APPROVAL: Listed as a commercial fire alarm control unit for use with separately listed initiating and



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **July 01, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division

indicating devices. Refer to listee's Installation Instruction Manual for details.



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2018**

Listing Expires **July 01, 2018**

Authorized By: **DAVID CASTILLO**, Program Coordinator
Fire Engineering Division