

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1615:0215 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263
Email: jon.wolski@us.bosch.com

DESIGN: Models F220-B6PM and -B6PS detector bases. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: F220-B6PM = 18.9 Vdc - 28Vdc
F220-B6PS = 9.6Vdc - 28 Vdc

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and UL label.

APPROVAL: Listed as detector bases for use with listee's separately listed fire alarm control units and Models F220-135 series (CSFM Listing No. 7270-1615:108), heat detectors; Models F220-PC series (CSFM Listing No. 7272-1615:107) or Models F220-P series (CSFM Listing No. 7272-1615:106) photoelectric smoke detectors. Refer to listee's Installation Instruction Manual for details.

01-08-2005



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division