

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 7300-1004:0106

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** Apollo America Inc. 25 Corporate Dr., Auburn Hills, MI 48326  
Contact: John Schertel (248) 332-3900 Fax (248) 332-8807  
Email: John.Schertel@apollo-fire.com

**DESIGN:** Models MR-101/T, \*MR-101-SSE/T, MR-104/T, \*MR-104-SSE/T, \*MR-201-SSE/T, MR-201/T, \*MR-204-SSE/T, MR-204/T, \*MR-RIC-301/T, \*MR-RIC-305/T, \*MR-RIC-401/T, \*MR-RIC-405/T, and \*MR-ITM/T relay modules. Refer to listee's data sheet for detailed product description and operational considerations.

**RATING:** 120 VAC, 18-35 VDC

**INSTALLATION:** In accordance with listee's printed installation instruction, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, electrical rating and UL label.

**APPROVAL:** Listed as relay modules for use with separately listed compatible fire alarm control units. Refer to listee's Installation Instruction Manual for details.

**NOTE:** 1. Formerly Air Products and Controls, Inc.

\*Rev. 04-03-14 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*