

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7272-1615:0175 Page 1 of 1

CATEGORY: 7272 -- SMOKE DETECTOR-SYSTEM TYPE-PHOTOELECTRIC

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263
Email: jon.wolski@us.bosch.com

DESIGN: Models D7050, D7050TH and *D7050DH addressable photoelectric type smoke detectors. Model D7050TH employs an integral 135o fixed temperature heat sensor. This heat sensor is intended for use only as a supplemental device to assist the smoke detector. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Supplied by Model D7024 series fire alarm control unit through a multiplex bus.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, *date code and UL label.

APPROVAL: Listed as photoelectric smoke detectors for use only with listee's separately listed Model D7024 (CSFM Listing No. 7165-1615:147) series fire alarm control unit. Units must be connected to the multiplex bus of the fire alarm control unit for both power and signaling. Model D7050 and D7050TH are intended for use with listee's Model D7050-B6 Base (CSFM Listing No. 7300-1615:176). Model D7050DH is intended for use with listee's Model D343 duct detector housing (CSFM Listing No. 3240-1615:181).

*Rev. 05-29-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division