

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7300-1615:0135 Page 1 of 1

CATEGORY: 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

LISTEE: BOSCH SECURITY SYSTEMS 130 Perinton Parkway, Fairport, NY 14450
Contact: Jon Wolski (585) 678-3323 Fax (585) 678-3263
Email: jon.wolski@us.bosch.com

DESIGN: Models D306 remote test/indicator and D307 remote indicator. *Models D308, D344-RT and D344-RL test kits. Models DRA-5 and DRA-12/24 remote annunciators. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: *D306, D307, D308, D344-RT, D344-RL 10 - 32 VDC
*DRA-5 5 VDC
*DRA-12/24 12 - 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as accessories for use with listee's separately listed detection devices. Models D306, D307, *D308, *D344-RT and *D344-RL for use with listee's separately listed Models D296 and D297 (CSFM Listing No. 7260-1615:132) beam smoke detection system.

Model DRA-5 for use with listee's separately listed Models D287, D292, D293A, D293E, and D293S (CSFM Listing No. 7300-1615:133) and Models D340 (CSFM Listing No. 3240-1615:184) D341, D342, and D343 (CSFM Listing No. 3240-1615:181) duct smoke detector housings. Model DRA-12/24 for use with listee's separately listed Model D7050-B6 (CSFM Listing No. 7300-1615:176) smoke detector base. Refer to listee's Installation Instruction Manual for details.

NOTE: Formerly 7300-0801:163

*Rev. 05-29-2007 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **October 10, 2017**

Listing Expires **June 30, 2018**

Authorized By: **DAVID CASTILLO, Program Coordinator**
Fire Engineering Division