CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7165-1657:0306 Page 1 of 2

CATEGORY: 7165 -- FIRE ALARM CONTROL UNIT (COMMERCIAL)

LISTEE: EDWARDS, A Division of UTC Fire & Security Americas Corporation, Inc.8985 Town Center

Parkway, Bradenton, FL 34202

Contact: Jewell Conover (941) 739-4358 Fax (941) 308-8123

Email: rhonda.micochero@fs.utc.com

DESIGN: EST Brand-3X-SFS1B(i) and 3XSFS1R(i) Fire alarm control systems. Refer to listee's data

sheet for additional detailed product description and operational considerations. System

subassemblies:

3X-PMI, 4X-12/S1GY, 4X-12/S1RY, 4X-12SR, 4X-24R, 4X-6/3S1G2Y, 4X-6/3SIGYR, 4X-4/3SGYWR, 4X-DR, 4X-LRMF, SFS1-CPU, 4X-LCD(-LC)3X-ETH1, 3X-FIB8, 3X-NET8,

3X-NET SFS1(i)-ELEC, CLA-PS10, PS10-4B, 4X-CAB6DR, 4X-CAB6D, CAB6B

Components:

3-SDC, 3-SDC1: Signature Data Card

3-CCI: City Module

URSM: Universal Riser Supervisory Module

RM1: Supervisory Module

MN-COMIS, 3-FIBMNB2, MN-ABPM, 3-ATPINT, ATPC: Interface Modules

PT1-S: System Printer

PT1-P: System Printer Paralle

3-NSHM1, 3-NSHM2: Modern Communication Cards

MN-NETSW1: Network Switching Hub MN-PASM: Audio Preamp Module MN-FVPN: VoIP Encoding/Decoding Unit

SMXL02, SMXHI2, SMXXLO, SMXHI, MMXVR: Fiber Transceiver

3X-PMI: Paging Microphone Interface

3-SSDC1, 3-SDDC1: Single Signature Drive Controllers 3-ZA20A, 3-ZA20B, 3-ZA40A, 3-ZA40B: Amplifiers 3-MODCOM, 3-MODCOMP: Modem Dialers 3-AADC1: Addressable Analog Module 3-IDC 8/4: Initiating Device Circuit Module

CDR-3: PSNI Coder Module

3-OPS: Off Premise Signaling Module

RATING: 120 VAC 50/60HZ, 240 VAC 50/60HZ, 24VDC

INSTALLATION: In accordance with listee's printed installation instructions, NFPA 72, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

*Rev. 04-04-13 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2015 Listing Expires July 01, 2015

Authorized By: JAMES PARSEGIAN, Program Coordinator

Fire Engineering Division

Listing No. 7165-1657:0306 Page 2 of 2

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and

indicating devices. *Suitable for high-rise applications. These control units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2010 edition and UL Standard 864 9th edition. Refer to

manufacturer's Installation Manual for details.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum

Retard/Reset/Restart period shall not exceed 30 seconds.

Alarm Verification shall not be implemented on initiation-device circuits that have the option of releasing and extinguishing agent or water unless these circuits release independently of

the Alarm Verification feature.

*Rev. 04-04-13 bh



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: July 01, 2015 Listing Expires July 01, 2015

Authorized By: JAMES PARSEGIAN, Program Coordinator

Fire Engineering Division