

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 7125-0785:0168

Page 1 of 1

CATEGORY: 7125 -- FIRE ALARM DEVICES FOR THE HEARING IMPAIRED

LISTEE: Cooper Wheelock Inc. 7246 16th St. E., Ste. 105, Sarasota, FL 34243
Contact: Tom Conover (941) 487-2336
Email: thomas.conover@cooperindustries.com

DESIGN: Exceder Series: Models ST strobe, HS horn strobe and HN horn. Model ST is a synchronous and non-synchronous strobe light. Model HS a visual/audible appliance and Model HN is an audible signal appliance. All units followed by R (red) or W (white). Additionally, a 'C' may be added for ceiling models and/or a '-NR' may be added for non-resettable models. For non -NR models and optional 'S' for silver fascia may be added*. Refer to listee's data sheet for additional detailed product description and operational considerations.

RATING: Electrical: 12 VDC/24VDC/FWR
Candela (wall)*: 15, 15/75, 30, 75, 95, 110, 135 & 185
Candela (ceiling)*: 15, 30, 60, 75, 95, 115, 150, & 177

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. All models are for indoor use and for wall mount only or ceiling mount only*

MARKING: Listee's name, model number, electrical/candela rating, and UL label.

APPROVAL: Listed as horn for fire alarm signaling and strobe, horn/strobe for the hearing impaired when used with separately listed electrically compatible fire alarm control units. Refer to listee's Installation Instructions Manual for details.

*Rev. 9-24-09 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2015**

Listing Expires **June 30, 2016**

Authorized By: **JAMES PARSESIAN, Program Coordinator**
Fire Engineering Division